



4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

November 10, 2016

Mr. Nick Titus
Pioneer Central School District
12125 County Line Road
PO Box 579
Yorkshire, New York 14173

re: Lead Testing in School Drinking Water

Dear Mr. Titus:

This letter is provided by Stohl Environmental LLC and includes results of Lead Testing in School Drinking Water for the following educational building(s):

- Delevan Elementary School

This letter is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The collection of water samples was performed by School District staff on 9/24/2016 following the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools". The water samples were then delivered by the School District to Stohl Environmental following strict chain-of-custody protocols. Once received, the water samples were then transmitted by Stohl Environmental to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP) following strict chain-of-custody protocols.

As detailed below, based on the laboratory results, 7 sources of potable water in Delevan Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions are required by the District as identified below.

Laboratory reports and Chain of Custody forms are included as attachments to this letter.

A MEMBER OF THE STOHL GROUP OF COMPANIES

Summary of Sampling and Analysis

Total Number of Samples Collected by Building Classified by First Draw

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Delevan Elementary	9/24/2016	89	82	7

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples				
Sample #	Sample Type	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
34	First Draw	39-Credit Union Faucet	Not Listed	36.0
39	First Draw	45-Special Ed. Area	Not Listed	44.0
40	First Draw	46-3 rd Grade Wing	Not Listed	26.4
47	First Draw	64-Special Ed. Area	Not Listed	31.5
48	First Draw	65-Computer Lab-Faucet	Not Listed	45.0
85	First Draw	Girl's Coaches Office	Not Listed	17.5
89	First Draw	80-Faucet	Not Listed	40.2

A MEMBER OF THE STOHL GROUP OF COMPANIES


Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

Thank you for the opportunity to be of service to Pioneer Central School District.

Sincerely,
Stohl Environmental, LLC.



William K. Sisco
Senior Project Manager



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

Laboratory Analytical Reports

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6042934 **Location:**4-Principal's Restrm-Faucet **Result(ppb):** 5.70
Client No.:1

Lab No.:6042935 **Location:**10-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:2

Lab No.:6042936 **Location:**10A-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:3

Lab No.:6042937 **Location:**11-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:4

Lab No.:6042938 **Location:**11A-Kind. Wing-Faucets **Result(ppb):** 6.80
Client No.:5

Lab No.:6042939 **Location:**12-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:6


Lab No.:6042940 **Location:**12A-Kind. Wing-Faucets **Result(ppb):** 9.20
Client No.:7


Lab No.:6042941 **Location:**13-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:8

Lab No.:6042942 **Location:**13A-Kind. Wing-Faucets **Result(ppb):** 5.90
Client No.:9

Lab No.:6042943 **Location:**14-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:10

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6042944 **Location:**14A-Kind. Wing-Faucets **Result(ppb):** 7.50
Client No.:11

Lab No.:6042945 **Location:**15-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:12

Lab No.:6042946 **Location:**15A-Kind. Wing-Faucets **Result(ppb):** 2.50
Client No.:13

Lab No.:6042947 **Location:**16-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:14

Lab No.:6042948 **Location:**16A-Kind. Wing-Faucets **Result(ppb):** 7.20
Client No.:15

Lab No.:6042949 **Location:**17-Kind. Wing-Faucets **Result(ppb):** <2.00
Client No.:16


Lab No.:6042950 **Location:**17A-Kind. Wing-Faucets **Result(ppb):** 8.20
Client No.:17


Lab No.:6042951 **Location:**20-1st Grade Wing-Faucets **Result(ppb):** <2.00
Client No.:18

Lab No.:6042952 **Location:**21-1st Grade Wing-Faucets **Result(ppb):** <2.00
Client No.:19

Lab No.:6042953 **Location:**22-1st Grade Wing-Faucets **Result(ppb):** 3.80
Client No.:20

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6042954 **Location:**23-1st Grade Wing-Faucets **Result(ppb):** <2.00
Client No.:21

Lab No.:6042955 **Location:**24-1st Grade Wing-Faucets **Result(ppb):** 6.30
Client No.:22

Lab No.:6042956 **Location:**25-1st Grade Wing-Faucets **Result(ppb):** 3.60
Client No.:23

Lab No.:6042957 **Location:**26-1st Grade Wing-Faucets **Result(ppb):** 12.2
Client No.:24

Lab No.:6042958 **Location:**27-1st Grade Wing-Faucets **Result(ppb):** 2.90
Client No.:25

Lab No.:6042959 **Location:**30-Special Ed. Area-Faucet **Result(ppb):** 3.00
Client No.:26


Lab No.:6042960 **Location:**31-Faculty Rm-Faucet **Result(ppb):** 4.10
Client No.:27


Lab No.:6042961 **Location:**32-Custodial-Faucet **Result(ppb):** 3.50
Client No.:28

Lab No.:6042962 **Location:**32-Custodial Restroom-Faucet **Result(ppb):** <2.00
Client No.:29

Lab No.:6042963 **Location:**33-Music Rm-Faucet **Result(ppb):** 4.40
Client No.:30

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6042964 **Location:**34A-Art Rm-Faucet **Result(ppb):** 6.80
Client No.:31

Lab No.:6042965 **Location:**34B-Art Rm-Faucet **Result(ppb):** 2.90
Client No.:32

Lab No.:6042966 **Location:**34C-Art Rm-Faucet **Result(ppb):** 4.20
Client No.:33

Lab No.:6042967 **Location:**39-Credit Union-Faucet **Result(ppb):** 36.0
Client No.:34

Lab No.:6042968 **Location:**40-4th Grade Wing-Faucet **Result(ppb):** 2.90
Client No.:35

Lab No.:6042969 **Location:**41-4th Grade Wing-Faucet **Result(ppb):** <2.00
Client No.:36


Lab No.:6042970 **Location:**42-4th Grade Wing-Faucet **Result(ppb):** 4.80
Client No.:37


Lab No.:6042971 **Location:**43/44-4th Grade Wing-Faucet **Result(ppb):** 9.40
Client No.:38

Lab No.:6042972 **Location:**45-Special Ed. Area **Result(ppb):** 44.0
Client No.:39

Lab No.:6042973 **Location:**46-3rd Grade Wing **Result(ppb):** 26.4
Client No.:40

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6042974 **Location:**47-3rd Grade Wing **Result(ppb):** <2.00
Client No.:41

Lab No.:6042975 **Location:**48-4th Grade Area-Faucets **Result(ppb):** <2.00
Client No.:42

Lab No.:6042976 **Location:**49-4th Grade Area-Faucets **Result(ppb):** 14.5
Client No.:43

Lab No.:6042977 **Location:**50-4th Grade Area-Faucets **Result(ppb):** 8.10
Client No.:44

Lab No.:6042978 **Location:**51-4th Grade Area-Faucets **Result(ppb):** 4.30
Client No.:45

Lab No.:6042979 **Location:**63-Special Ed. Area **Result(ppb):** 9.50
Client No.:46


Lab No.:6042980 **Location:**64-Special Ed. Area **Result(ppb):** 31.5
Client No.:47


Lab No.:6042981 **Location:**65-Computer Lab-Faucets **Result(ppb):** 45.0
Client No.:48

Lab No.:6042982 **Location:**66/66A-LMC **Result(ppb):** Sample Not Received
Client No.:49

Lab No.:6042983 **Location:**68-2nd Grade Wing-Faucets **Result(ppb):** Sample Not Received
Client No.:50

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6042984 **Location:**69-2nd Grade Wing-Faucets **Result(ppb):** 10.0
Client No.:51

Lab No.:6042985 **Location:**70-2nd Grade Wing-Faucets **Result(ppb):** 5.80
Client No.:52

Lab No.:6042986 **Location:**71-2nd Grade Wing-Faucets **Result(ppb):** <2.00
Client No.:53

Lab No.:6042987 **Location:**71A-2nd Grade Wing-Faucets **Result(ppb):** 3.20
Client No.:54

Lab No.:6042988 **Location:**72-2nd Grade Wing-Faucets **Result(ppb):** <2.00
Client No.:55

Lab No.:6042989 **Location:**Nurse's Restroom Faucet **Result(ppb):** <2.00
Client No.:56


Lab No.:6042990 **Location:**Nurse's Restroom Faucet **Result(ppb):** 4.20
Client No.:57


Lab No.:6042991 **Location:**Kinder. Hall Drinking Fountain Cooler **Result(ppb):** <2.00
Client No.:58 A Elkay

Lab No.:6042992 **Location:**Kinder.Hall Drinking Fountain Cooler **Result(ppb):** <2.00
Client No.:59 B Elkay

Lab No.:6042993 **Location:**1st Grade Wing Drinking Elkay Cooler **Result(ppb):** <2.00
Client No.:60

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219


Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:


Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6042994 Client No.: 61A	Location: 1st Grade Boy's Restroom-Sink	Result(ppb): 8.80
Lab No.: 6042995 Client No.: 61B	Location: 1st Grade Boy's Restroom-Sink	Result(ppb): 3.00
Lab No.: 6042996 Client No.: 62A	Location: 1st Grade Girl's Restroom-Sink	Result(ppb): 2.90
Lab No.: 6042997 Client No.: 62B	Location: 1st Grade Girl's Restroom-Sink	Result(ppb): 4.70
Lab No.: 6042998 Client No.: 63	Location: 1st Wing Faculty Restroom-Faucet	Result(ppb): <2.00
Lab No.: 6042999 Client No.: 64	Location: 1st Grade Handicap Restroom	Result(ppb): Sample Not Received
Lab No.: 6043000 Client No.: 65A	Location: 2nd Grade Boy's Restroom-Sink	Result(ppb): 7.80
Lab No.: 6043001 Client No.: 66B	Location: 2nd Grade Boy's Restroom-Sink	Result(ppb): 3.30
Lab No.: 6043002 Client No.: 67A	Location: 2nd Grade Girl's Restroom-Sink	Result(ppb): 4.40
Lab No.: 6043003 Client No.: 68B	Location: 2nd Grade Girl's Restroom-Sink	Result(ppb): 3.20

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6043004 **Location:**4th Grade Drinking Elkay Cooler **Result(ppb):** <2.00
Client No.:69

Lab No.:6043005 **Location:**4th Grade Boy's Locker Room-Faucet **Result(ppb):** 3.10
Client No.:70

Lab No.:6043006 **Location:**4th Grade Girl's Locker Room-Faucet **Result(ppb):** 2.90
Client No.:71

Lab No.:6043007 **Location:**4th Grade Faculty Restroom-Sink **Result(ppb):** 2.50
Client No.:72

Lab No.:6043008 **Location:**Cafe Hall Drinking A-Elkay Cooler **Result(ppb):** <2.00
Client No.:73

Lab No.:6043009 **Location:**Cafe Hall Drinking B-Elkay Cooler **Result(ppb):** <2.00
Client No.:74

Lab No.:6043010 **Location:**Kitchen Restroom-Sink **Result(ppb):** 4.50
Client No.:75

Lab No.:6043011 **Location:**Kitchen A-Sink **Result(ppb):** 14.1
Client No.:76

Lab No.:6043012 **Location:**Kitchen B-Sink **Result(ppb):** 12.9
Client No.:77

Lab No.:6043013 **Location:**Kitchen C-Sink **Result(ppb):** 8.20
Client No.:78

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016

Date Analyzed: 11/02/2016

Signature: 

Analyst: Chad Shaffer

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6043014 **Location:**Auditorium Restroom Boy's-Faucet **Result(ppb):** 4.20
Client No.:79

Lab No.:6043015 **Location:**Auditorium Restroom Girl's-Faucet **Result(ppb):** <2.00
Client No.:80

Lab No.:6043016 **Location:**Additional Samples Received - D **Result(ppb):** 4.60
Client No.:81 Hand Wash Sink #2

Lab No.:6043017 **Location:**Additional Samples Received - Library **Result(ppb):** 3.10
Client No.:82 West

Lab No.:6043018 **Location:**Additional Samples Received - Library **Result(ppb):** <2.00
Client No.:83 East

Lab No.:6043019 **Location:**Additional Samples Received - **Result(ppb):** 3.30
Client No.:84 Handwashing Sink #1 Kitchen


Lab No.:6043020 **Location:**Additional Samples Received - Girl's **Result(ppb):** 17.5
Client No.:85 Coaches Office


Lab No.:6043021 **Location:**Additional Samples Received - Girl's **Result(ppb):** 2.00
Client No.:86 Gym Locker Rm Sink

Lab No.:6043022 **Location:**Additional Samples Received - Boy's **Result(ppb):** 14.9
Client No.:87 Coaches Office

Lab No.:6043023 **Location:**Additional Samples Received - Boy's **Result(ppb):** 6.20
Client No.:88 Coaches Locker Rm

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016
Date Analyzed: 11/02/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6043024
Client No.:89

Location:Additional Samples Received - 80
Faucet

Result(ppb): 40.2

Lab No.:6043025
Client No.:90

Location:Additional Samples Received - 81
Faucet

Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 9/28/2016

Date Analyzed: 11/02/2016

Signature: 

Analyst: Chad Shaffer

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 11/2/2016
Report No.: 520649 - Lead Water
Project: Pioneer Central School - Delevan Elementary
9/24/16
Project No.:

Client: STO708

Appendix to Analytical Report:

Customer Contact: Lab Results Final
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

Chains of Custody

	Location	Location	Outlet Type	
1	4 Principal's Restrm		Faucet	-6042934
2	10	Kind. Wing	Faucets	-6042935
3	10A			-6042936
4	11			-6042937
5	11A			-6042938
6	12			-6042939
7	12A			-6042940
8	13			-6042941
9	13A			-6042942
10	14			-6042943
11	14A			-6042944
12	15			-6042945
13	15A			-6042946
14	16			-6042947
15	16A			-6042948
16	17			-6042949
17	17A			-6042950
18	20	1st oz wing	Faucets	-6042951
19	21			-6042952
20	22			-6042953
21	23			-6042954
22	24			-6042955
23	25			-6042956
24	26			-6042957
25	27			-6042958
26	30	SpEd Area	Faucet	-6042959
27	31	Faculty Rm	Faucet	-6042960
28	32	Custodial	Faucet	-6042961
29	32 Custodial Restrm		"	-6042962
30	33	Music Rm	Faucet	-6042963
31	34A	Art Rm	Faucet	-6042964
32	34B			-6042965
33	34C			-6042966
34	39	Credit Union	Faucet	-6042967
35	40	4th wing	Faucet	-6042968
36	41			-6042969
37	42			-6042970
38	43/44			-6042971
39	45	SpEd Area		-6042972
40	46	3rd Gr Wing		-6042973
41	47			-6042974

START Time 9:15 Am
 10:45 Am
 Saturday 27th 2016

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41

42	48	4th Gr Area	Faucets	6042975
43	49			6042976
44	50			6042977
45	51			6042978
46	63	SPEA AREA		6042979
47	64			6042980
48	65	Computer Lab	Faucets	6042981
49	66 + Lc6A	Lmc		6042982*
50	68	2nd Gr Wing	Faucets	6042983*
51	69			6042984-us
52	70			6042985-64
53	71			6042986-70
54	71A			6042987
55	72			6042988
56	Nurse's Restrm -		2 FAUCETS	< Bathroom Faucet 6042989 Faucet 6042990
57	Kinder Hall Drinking A	Kind Wing	Elkay Cooler	← 6042991
58	Kinder Hall Drinking B		"	← 6042992
59	1st Gr Drinking	1st Gr Wing	Elkay Cooler	← 6042993
60A	1st Gr Boys Restrm		Sinks	< A 6042994 B 6042995
60B	1st Gr Girls Restrm		Sinks	< A 6042996 B 6042997
61	1st-Gr Fac Restrm		FAUCET	6042998
62	1st Gr Handicap Restrm		FAUCET	6042999*
63	2nd-Gr-Drinking		Elkay Cooler	No Test
63A	2nd Gr Boys Restrm		Sink	< A 6043000 B 6043001
63B	2nd Gr Girls Restrm		Sink	< A 6043002 B 6043003
67	3rd Gr Boys Restrm		Sink	
68	3rd Gr Girls Restrm		Sink	
69	4th Gr Drinking		Elkay Cooler	6043004
70 4th Gr	Boy's Locker Rm		Faucet	6043005
71 4th Gr	Girl's Locker Rm		Faucet	6043006
72	4th Gr Fac Restrm		Sink	6043007
73	Café Hall Drinking A		Elkay Cooler	6043008
74	Café Hall Drinking B		Elkay Cooler	6043009
75	Café Drinking		No Test	
76	Kitchen Restrm		Sink	6043010
77	Kitchen A			6043011 ✓
78	Kitchen B			6043012
79	Kitchen C			6043013
80	Kitchen D			
81	Kitchen E			
82	Auditorium Restrm Boys		FAUCET	6043014
83	Auditorium Restrm Girls		"	6043015

* Sample Not Rec'd

iATL 6042982

iATL 6042983

Sample Not Rec'd
iATL 6042999

Additional Samples Rec'd
• see attached

