



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 192158

Matrix Drinking Water
Received 11/15/16
Reported 11/17/16

Attn:
Project: Pioneer Middle School
Location: Old Olean Rd Yorkshire NY
Number: 2016L-107A

PO Number:

Sample ID	Cust. Sample ID	Location	Method	Result	RL*	Units	Analysis Date	Analyst
192158-001	ME25-R	E146						
Metals Analysis								
Lead		EPA 200.9 Rev 2.2		<5.00	5.00	µg/L	11/16/16	MH
192158-002	ME26-R	E146						
Metals Analysis								
Lead		EPA 200.9 Rev 2.2		<5.00	5.00	µg/L	11/16/16	MH
192158-003	E42-R	Lower						
Metals Analysis								
Lead		EPA 200.9 Rev 2.2		<5.00	5.00	µg/L	11/16/16	MH
192158-004	E42-R	Upper						
Metals Analysis								
Lead		EPA 200.9 Rev 2.2		<5.00	5.00	µg/L	11/16/16	MH

192158-11/17/16 08:59 AM

Abisola O Kasali

Reviewed By: **Abisola Kasali**
Metals Supervisor

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 192158

Matrix: Drinking Water
Received: 11/15/16
Reported: 11/17/16

Attn:
Project: Pioneer Middle School
Location: Old Olean Rd Yorkshire NY
Number: 2016L-107A

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL*, Units, Analysis Date, Analyst

Certifications

Table with columns: Parameter, Method, Matrix, CA, CT, FL, NJ, NY, RI, VA. Row for Lead with EPA 200.9 Rev 2.2 method and 'X' marks for all states.

Key

Table with 3 columns: State, Regulatory Agency - Lab ID, Certificate Number. Lists states CA, CT, FL, NJ, NY, RI, VA and their corresponding agencies and certificate numbers.

'X' indicates that the analyte is accredited.

If your state is not listed above, call laboratory for accreditation/certification information.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Chain of Custody Document

Submitted to: (Lab Name) Schneider Labs

STOHL Job # 2016L-107A

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
 ☎ (716) 312-0070 ■ (716) 312-8092
 www.stohlenvironmental.com

Client: Pioneer CSD

Contact: Nick Titus

Building: Pioneer Middle School

Location: Old Olean Rd, Yorkshire NY 14173

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
ME25-R	E146	Faucet	22:00			
ME26-R	E146	Faucet	22:00			
E42-R	Lower	Faucet	22:00			
E42-R	Upper	Faucet	22:00			

192158 S 4

V:192192158
 jandrews 11/15/2016 1:50:00 PM
 Federal Express

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: dbanach@stohlenv.com

Sampled By: Michael B Titus Print Name Nick Titus Date: 11/10/2016
 Relinquished By: Derek Banach Print Name Derek Banach Date: 11/11/2016
 Received (Name / Lab): _____ Date: _____ Time: _____
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____